



Scenariu de accident cu explozie la Coloana de rectificare 140-C2  
IR\_140C2\_UVCE



			ID_Eveniment	IR_140C2_UVCE	an <sup>-1</sup>
			Instalatie	Coloana de rectificare 140-C2	
			Tip_Eveniment	UVCE	
			Substanta	Benzina	
			Localitate	Ploiesti	
			Frecventa	1E-05	
	Mortalitate ridicata	0.3 bari	Zona_I	42	m
	Prag de mortalitate	0.14 bari	Zona_II	71	m
	Vătămări ireversibile	0.07 bari	Zona_III	121	m
	Vătămări reversibile	0.03 bari	Zona_IV	233	m

Scale: 1:5.000

480 Meters