

Scenariu de accident cu explozie la Rezervorul de light naphtha tip II A23
IAFPE_A23_CVE



	ID_Eveniment	IAFPE_A23_CVE	
	Instalatie	Rezervorul de light naphtha tip II - A23	
	Tip_Eveniment	CVE	
	Substanta	Light naphtha tip II	
	Localitate	Ploiesti	
	Frecventa	1E-06	an ⁻¹
	Zona_I	42	m
	Zona_II	70	m
	Zona_III	119	m
	Zona_IV	230	m

	Mortalitate ridicata	0.3 bari
	Prag de mortalitate	0.14 bari
	Vătămări ireversibile	0.07 bari
	Vătămări reversibile	0.03 bari

0 120 240 480 Meters

Scale: 1:5,000

Google