

**SITUATIA FORAJELOR DIN FRONTUL DE CAPTARE APA POTABILA N-V PLOIESTI**

Numarul forajului	Zona de protectie sanitara (cf studiului), m				Locul unde zona de protectie cu regim sever nu este respectata prin imprejmuire	
	cu regim sever		cu regim de restrictie			
	amonte	aval	amonte	aval		
1	81.3	62.7	138.6	91.9	lateral stanga	
2	47.4	28.7	86.1	39.4		aval
3	nefunctionabil					
4	57.6	38.9	101.8	55.1		
5	70.9	52.3	122.4	75.7		aval
6	74.6	55.9	128.1	81.4		aval
7	99.2	80.5	166.5	119.9	amonte	aval - British Tabaco
8	89.5	70.8	151.3	104.6	amonte	aval - British Tabaco
9	71.8	53.1	123.7	77.1	amonte	
10	87.1	68.4	147.6	100.9	amonte	
11	102.3	83.6	171.4	124.7	amonte	aval
12	102.4	83.8	171.7	125	amonte	aval
13	120.9	102.2	200.6	153.9	amonte	aval